

Transfield Services Limited

Eastlink Ambient Air Quality Monitoring System Report

1st January 2011 – 31st March 2011

Report issue date: 14th April 2011

Maintenance contract: MC621





| Customer Details | |
|------------------|--|
| Customer | Transfield Services Ltd |
| Contact name | Alex Monson |
| Address | Transfield Services PO Box 804 Ringwood VIC 3134 |
| Email | amonson@connecteast.com.au |
| Phone | 03 9755 1716 |

| Revision History | | | |
|------------------|----------|----------|---------|
| Report | Revision | Date | Analyst |
| DAT5011 | 0 | 14/04/11 | DD |
| | | | |
| | | | |
| | | | |

Report by David Ding *David Ding*
(name) (signature)

NATA Signatory/Signatory Jon Alexander *[Signature]*
(name) (signature)



CONTENTS

| | |
|--|----|
| Customer Details | 2 |
| Revision History | 2 |
| 1.0 Executive Summary | 4 |
| 2.0 Introduction | 5 |
| 3.0 Monitoring and Data Collection | 5 |
| 3.1 Station Parameters | 6 |
| 3.2 Data Collection Methods..... | 7 |
| 3.2.1 Data Acquisition | 8 |
| 3.3 Data Validation and Reporting | 9 |
| 3.3.1 Validation | 9 |
| 3.3.2 Reporting | 9 |
| 4.0 Air Quality Goals | 10 |
| 5.0 Calibrations and Maintenance | 10 |
| 5.1 Units and Uncertainties | 10 |
| 5.2 Maintenance | 12 |
| 6.0 Results | 15 |
| 6.1 Percentage Availability | 15 |
| 6.2 Graphical Reports | 18 |
| 7.0 Valid Data Exception Tables..... | 24 |
| 8.0 Discussion | 34 |
| Appendix 1 | 35 |
| Appendix 2 | 36 |



1.0 Executive Summary

EastLink is a motorway, which runs between Donvale in Melbourne's north east, to Frankston in the south-east of Melbourne. Transfield services are responsible for the operation and maintenance of the 39 kilometre road and have commissioned Ecotech P/L to monitor the ambient air quality outside the two Eastlink tunnels and provide maintenance and reporting services. CO, NOx and particulate data are monitored, along with meteorological data. Monitoring of these parameters allows any changes in the ambient air quality to be quickly identified and recorded.

The three ambient Eastlink sites are located around the north east end of the Eastlink freeway at Chaim Crt, Craig Rd and Heads Rd. Ecotech P/L commenced monitoring of these sites on June 16th 2010.

The overall percentage availability at Chaim Crt and Craig Rd was above 95% for the reporting period. At Heads Rd, the overall percentage availability fell below this threshold at 94%.

No readings over the State Environmental Planning Policy (MARP) intervention levels were recorded during the reporting period.

2.0 Introduction

Ecotech P/L was commissioned by Transfield Services to provide monitoring and data reporting for the Eastlink ambient air quality monitoring network, located as detailed in Table 1. Ecotech commenced data collection from the Eastlink network on the 16th June 2010.

This report presents the data for the period January to March 2011.

The data presented in this report:

- Describes air quality measurements
- Compares monitoring results
- Has been quality assured
- Complies with NATA accreditation requirements, where applicable

3.0 Monitoring and Data Collection

The Eastlink monitoring network consists of three ambient air quality monitoring stations. Station locations and parameters monitored are described below.

Table 1: Eastlink monitoring network sites geographical co-ordinates

| Site Name | Geographical Coordinates |
|-----------|-------------------------------|
| Chaim Crt | 37°48'30.55"S, 145°12'36.59"E |
| Craig Rd | 37°48'7.85"S, 145°12'24.14"E |
| Heads Rd | 37°48'7.39"S, 145°11'43.50"E |

A siting audit conducted on 17 June 2010 showed that the siting of the Chaim Crt and Craig Rd sites complies with *AS/NZS 3580.1.1:2007 Methods for sampling and analysis of ambient air*. The Heads Rd site does not comply with the above standard as the monitoring equipment is situated too close to trees.

These sites are classified as neighbourhood stations according to *AS/NZS 3580.1.1:2007 Methods for sampling and analysis of ambient air*.

3.1 Station Parameters

The Eastlink monitoring stations are equipped to measure the following parameters:

Table 2: Parameters measured at the Eastlink ambient monitoring sites

| Station | Parameter Measured | Instrument |
|-----------|---------------------------------------|--------------------------------------|
| Chaim Crt | NO, NO ₂ , NO _x | Ecotech EC9841 |
| | CO | Ecotech EC9830 |
| | PM ₁₀ | Rupprecht & Patashnick TEOM |
| | PM _{2.5} | Rupprecht & Patashnick TEOM FDMS |
| | Wind Speed | Vaisala WS425 |
| | Wind Direction | Vaisala WS425 |
| | Ambient Temperature | Vaisala HMP45A |
| | Relative Humidity | Vaisala HMP45A |
| | Solar Radiation | Middleton Solar Pyranometer SK-01-D2 |
| Craig Rd | NO, NO ₂ , NO _x | Ecotech EC9841 |
| | CO | Ecotech EC9830 |
| | PM ₁₀ | Rupprecht & Patashnick TEOM |
| | Wind Speed | Vaisala WS425 |
| | Wind Direction | Vaisala WS425 |
| | Ambient Temperature | Vaisala HMP45A |
| | Relative Humidity | Vaisala HMP45A |
| Heads Rd | NO, NO ₂ , NO _x | Ecotech EC9841 |
| | CO | Ecotech EC9830 |
| | PM ₁₀ | Rupprecht & Patashnick TEOM |
| | Wind Speed | Vaisala WS425 |
| | Wind Direction | Vaisala WS425 |
| | Ambient Temperature | Vaisala HMP45A |
| | Relative Humidity | Vaisala HMP45A |

3.2 Data Collection Methods

The following methods are used for data collection:

Table 3: Methods

| Parameter Measured | Method | Description |
|---------------------------------------|---------------------|---|
| NO, NO ₂ , NO _x | AS 3580.5.1-1993 | Methods for sampling and analysis of ambient air. Method 5.1: Determination of oxides of nitrogen – Chemiluminescence method |
| CO | AS 3580.7.1-1993 | Methods for sampling and analysis of ambient air. Method 7.1: Determination of carbon monoxide – Direct-reading instrumental method |
| PM ₁₀ (TEOM) | AS 3580.9.8-2008 | Methods for sampling and analysis of ambient air. Method 9.8: Determination of suspended particulate matter - PM ₁₀ continuous direct mass method using a tapered element oscillating microbalance analyser. |
| PM _{2.5} (TEOM FDMS) | In-house method 7.3 | In-house Method 7.3: Determination of suspended particulate matter – PM ₁₀ and PM _{2.5} continuous direct mass method using a tapered element oscillating microbalance analyser. |
| Wind Speed | AS 2923-1987 | Ambient Air – Guide for measurement of horizontal wind for air quality applications |
| Wind Direction | AS 2923-1987 | Ambient Air – Guide for measurement of horizontal wind for air quality applications |

Table 3: Methods (continued)

| Parameter Measured | Method | Description |
|---------------------|---------------------|---|
| Sigma | AS 2923-1987 | Ambient Air – Guide for measurement of horizontal wind for air quality applications |
| Ambient Temperature | US EPA 454/R-99-005 | Meteorological Monitoring Guidance for Regulatory Modeling Applications |
| Relative Humidity | US EPA 454/R-99-005 | Meteorological Monitoring Guidance for Regulatory Modeling Applications |
| Solar Radiation | US EPA 454/R-99-005 | Meteorological Monitoring Guidance for Regulatory Modeling Applications |

Note: The horizontal wind sensor sitting does not meet the AS2923 requirements.

3.2.1 Data Acquisition

Data acquisition is done using a PC based WinAQMS logger (using WinCollect[®] Version 4.0 & WinAQMS[®] Version 2.0) situated at each of the three monitoring sites; Chaim Crt, Craig Rd and Heads Rd. Each logger is equipped with a 3G modem for remote data collection. The recorded data is remotely collected from the AQMS loggers on a daily basis and stored at Ecotech’s Environmental Reporting Services (ERS) department in Melbourne. Data samples are logged in 5 minute intervals.

3.3 Data Validation and Reporting

3.3.1 Validation

The Ecotech ERS department perform daily data checks to ensure maximum data capture rates are maintained. Any equipment failures are communicated to the responsible field engineers for urgent rectification. Ecotech ERS maintains two distinct databases containing non-validated and validated data respectively.

The validated database is created by duplicating the non-validated database and then flagging data affected by instrument faults, calibrations and other maintenance activities. The data validation software requires the analyst to supply a valid reason (e.g. backed by maintenance notes, calibration sheets etc) in the database for flagging any data as invalid.

Validation is performed by the operator, and the validation is reviewed. All data is checked and graphs and reports are generated based on the verified 5 minute data.

3.3.2 Reporting

The reported data is in 3 Microsoft Excel format files named “*Chaim Crt Data Report Jan_Mar11.xls*”, “*Craig Rd Data Report Jan_Mar11.xls*” and “*Heads Rd Data Report Jan_Mar11.xls*”.

Each Excel file consists of 4 Excel spreadsheets:

1. Cover
2. 1 Hour Data
3. 24 Hour Data
4. Valid Data Exception Table

The data contained in these reports is based on Australian Eastern Standard Time. Data is for all parameters measured continuously. All averages are calculated from the 5 minute data.

Averaging times are reported for the end of the period, i.e. the hourly average 02:00am is for the data collected from 1:00am to 2:00am.

4.0 Air Quality Goals

The air quality goal requirements for particulates at the Eastlink monitoring network sites are shown below.

Table 4: MARP Schedule B Intervention Levels

| Parameter | Time Period | Intervention Level | Units |
|-------------------|-------------|--------------------|-------------------|
| NO ₂ | 1 hour | 140 | ppb |
| CO | 1 hour | 29 | ppm |
| PM ₁₀ | 24 hour | 60 | µg/m ³ |
| PM _{2.5} | 24 hour | 36 | µg/m ³ |

5.0 Calibrations and Maintenance

5.1 Units and Uncertainties

The uncertainties for each parameter have been determined by the manufacturers tolerance limits of the equipment's parameters, and by the applicable Australian Standard.

Table 5: Units and Uncertainties

| Parameter | Units | Resolution | Uncertainty | Range |
|-----------------|-------|------------|------------------------------|------------------|
| NO | ppb | 1 ppb | ± 14 ppb K factor of 2.01 | 0 ppb to 500 ppb |
| NO ₂ | ppb | 1 ppb | ± 16 ppb K factor of 2.01 | 0 ppb to 500 ppb |
| NO _x | ppb | 1 ppb | ± 14 ppb K factor of 2.01 | 0 ppb to 500 ppb |
| CO | ppm | 0.1 ppm | ± 1.1 ppm K factor of 2 | 0 ppm to 50 ppm |

Table 5: Units and Uncertainties (continued)

| Parameter | Units | Resolution | Uncertainty | Range |
|-------------------------------|-------------------|-----------------------|--|---|
| PM ₁₀ (TEOM) | µg/m ³ | 0.1 µg/m ³ | ±5.0 µg/m ³ or 3.6% of reading, whichever is the greater K factor of 1.96 | 0 µg/m ³ to several g/m ³ |
| PM _{2.5} (TEOM FDMS) | µg/m ³ | 0.1 µg/m ³ | ±5.0 µg/m ³ or 3.6% of reading, whichever is the greater K factor of 1.96 | 0 µg/m ³ to several g/m ³ |
| Vector Wind Speed | m/s | 0.1 m/s | ±0.22 m/s or 3.0% of reading, whichever is greater K factor of 1.96 | 0 m/s to 15 m/s |
| Vector Wind Direction | Deg (°) | 1° | ±4.0° K factor 2.11 | 0° to 360° |
| Solar Radiation | W/m ² | 1 W/m ² | ± 5 % of reading or ±32 w/m ² or whichever is greater K factor of 1.96 | 0 to 1100 W/m ² |
| Ambient Temperature | °C | 0.1°C | ± 0.25°C K factor of 2.01 | 0°C to 50°C |
| Relative Humidity | % | 1% | ± 5% K factor of 2.31 | 0-100% |

The reported uncertainties are expanded uncertainties calculated using coverage factors which give a level of confidence of approximately 95%.

5.2 Maintenance

The last calibrations for the following parameters have been performed on the indicated date. Data supplied after this time is subject to verification to be performed at the next calibration cycle.

Tables 6, 7 and 8 indicate when the particulate, gas and meteorological equipment were last calibrated.

Table 6: Chaim Court Maintenance Table January to March2011

| Parameter | Scheduled Maintenance Performed | Date Scheduled Maintenance performed | Last Calibration Date |
|---------------------------------------|---------------------------------|--------------------------------------|-----------------------|
| NO, NO ₂ , NO _x | Yes | 16/03/11 | 16/03/11 |
| CO | Yes | 16/03/11 | 16/03/11 |
| PM ₁₀ | No | N/A | 19/01/11 |
| PM _{2.5} | No | N/A | 19/01/11 |
| Wind Speed* | No | 23/09/10 | 23/09/10 |
| Wind Direction* | No | 23/09/10 | 23/09/10 |
| Ambient Temperature | Yes | 17/03/11 | 17/03/11 |
| Relative Humidity | Yes | 17/03/11 | 17/03/11 |
| Solar Radiation** | No | N/A | TBA |

*Instrument covered by Ecotech's NATA scope of accreditation from the calibration date onwards

**Provision of this service not covered by NATA scope of accreditation as the instrument does not have a current calibration certificate.

Table 7: Craig Rd Maintenance Table January to March 2011

| Parameter | Scheduled Maintenance Performed | Date Scheduled Maintenance performed | Last Calibration Date |
|---------------------------------------|---------------------------------|--------------------------------------|-----------------------|
| NO, NO ₂ , NO _x | Yes | 28/03/11 | 28/03/11 |
| CO | Yes | 28/03/11 | 28/03/11 |
| PM ₁₀ | No | N/A | 18/01/11 |
| Wind Speed* | No | 24/09/10 | 24/09/10 |
| Wind Direction* | No | 24/09/10 | 24/09/10 |
| Ambient Temperature | Yes | 28/03/11 | 28/03/11 |
| Relative Humidity | Yes | 28/03/11 | 28/03/11 |

*Instrument covered by Ecotech's NATA scope of accreditation from the calibration date onwards

Table 8: Heads Rd Maintenance Table January to March 2011

| Parameter | Scheduled Maintenance Performed | Date Scheduled Maintenance performed | Last Calibration Date |
|---------------------------------------|---------------------------------|--------------------------------------|-----------------------|
| NO, NO ₂ , NO _x | Yes | 17/03/11 | 30/03/11 |
| CO | Yes | 17/03/11 | 30/03/11 |
| PM ₁₀ | No | N/A | 18/01/11 |
| Wind Speed* | No | 27/09/10 | 27/09/10 |
| Wind Direction* | No | 27/09/10 | 27/09/10 |
| Ambient Temperature | Yes | 17/03/11 | 17/03/11 |
| Relative Humidity | Yes | 17/03/11 | 17/03/11 |

*Instrument covered by Ecotech's NATA scope of accreditation from the calibration date onwards



ACCREDITED FOR
TECHNICAL
COMPETENCE



6.0 Results

6.1 Percentage Availability

Percentage availability is based on 1 hour averages, calculated from 5 minute data, and refers to the amount of available data collected for January to March 2011.

The percentage of available data is calculated using the following equation:

Availability = (Reported air quality data / Total data) x 100%

- Reported air quality data = Number of instrument readings which have been verified through a NATA or quality assured process as appropriate and excludes all data errors, zero data collection due to calibration, failures and planned and unplanned maintenance.
- Total data = Total number of instrument readings since the start of the term assuming no maintenance, errors, loss of data or calibration.

Table 9: Monthly Percentage Availability for Eastlink Sites for January to March 2011

| Parameter | Chaim Crt % | Craig Rd % | Heads Rd % |
|---------------------------------------|----------------|---------------|---------------|
| NO, NO ₂ , NO _x | 84 | 91 | 90 |
| CO | 95 | 92 | 88 |
| PM ₁₀ | 100 | 97 | 94 |
| PM _{2.5} | 94 | N/A | N/A |
| WS, WD, Sigma | 99 | 97 | 97 |
| AT | 100 | 97 | 98 |
| RH | 100 | 97 | 98 |
| SR | 100 | N/A | N/A |

* Bold values indicate Overall Percentage Availability below 95%

Table 10: Exceedences Above MARP Intervention Levels for January to March 2011

| Station | Parameter | Time Period | Value of Exceedence | Date of Exceedence |
|-----------|-------------------|-------------|---------------------|--------------------|
| Chaim Crt | NO ₂ | 1 hour | - | - |
| | CO | 1 hour | - | - |
| | PM ₁₀ | 24 hour | - | - |
| | PM _{2.5} | 24 hour | - | - |
| Craig Rd | NO ₂ | 1 hour | - | - |
| | CO | 1 hour | - | - |
| | PM ₁₀ | 24 hour | - | - |
| Heads Rd | NO ₂ | 1 hour | - | - |
| | CO | 1 hour | - | - |
| | PM ₁₀ | 24 hour | - | - |

6.2 Graphical Reports

Validated 5 minute data for NO, NO₂, NO_x, CO, PM₁₀, PM_{2.5}, wind speed and wind direction were used to construct the following monthly graphical representations.




Figure 1: CO 1-hour Averages for January to March 2011




Figure 2: Chaim Crt NO, NO₂, NO_x 1-hour Averages for January to March 2011




Figure 3: Craig Rd NO, NO₂, NO_x 1-hour Averages for January to March 2011




Figure 4: Heads Rd NO, NO₂, NO_x 1-hour Averages for January to March 2011




Figure 5: PM₁₀ 1-hour Averages for January to March 2011




Figure 6: PM_{2.5} 1-hour Averages for January to March 2011

7.0 Valid Data Exception Tables

Table 11: Chaim Crt Valid Data Exception Table

| Start Date | End Date | Reason | Change Details | User Name | Change Date |
|----------------|----------------|---|---------------------------------------|-----------|-------------|
| 4/01/11 10:05 | 20/01/11 12:25 | Intermittent additional automatic calibration checks | CO | DD | 21/02/2011 |
| 5/01/11 18:10 | 24/01/11 07:10 | Intermittent data affected by environmental conditions - wind speed spike | WS, WD, Sigma | DD | 21/02/2011 |
| 7/01/11 01:50 | 10/01/11 13:15 | Span out of tolerance | NO, NO ₂ , NO _x | DD | 21/02/2011 |
| 9/01/11 19:05 | 14/01/11 09:05 | TEOM drier fault | PM _{2.5} | DD | 21/02/2011 |
| 10/01/11 13:20 | 10/01/11 13:30 | Maintenance - Remote calibration | NO, NO ₂ , NO _x | DD | 21/02/2011 |
| 10/01/11 13:20 | 10/01/11 13:40 | Maintenance - Remote calibration | CO | DD | 21/02/2011 |
| 14/01/11 09:10 | 14/01/11 13:25 | Maintenance - Replaced dryer and instrument stabilisation | PM _{2.5} | DD | 21/02/2011 |
| 14/01/11 10:30 | 14/01/11 12:05 | Maintenance - TEOM filter change and instrument stabilisation | PM ₁₀ | DD | 21/02/2011 |
| 19/01/11 10:25 | 19/01/11 12:35 | Scheduled maintenance - monthly | NO, NO ₂ , NO _x | DD | 21/02/2011 |
| 19/01/11 11:20 | 19/01/11 12:35 | Scheduled maintenance - monthly | CO | DD | 21/02/2011 |
| 19/01/11 11:50 | 19/01/11 13:35 | Maintenance - TEOM filter change and instrument stabilisation | PM ₁₀ | DD | 21/02/2011 |
| 19/01/11 11:50 | 19/01/11 14:30 | Maintenance - TEOM filter change and instrument stabilisation | PM _{2.5} | DD | 21/02/2011 |
| 5/02/11 01:50 | 10/02/11 00:55 | Span out of tolerance | NO, NO ₂ , NO _x | DD | 9/03/2011 |

Table 11: Chaim Crt Valid Data Exception Table (continued)

| | | | | | |
|----------------|----------------|---|--|----|-----------|
| 5/02/11 09:45 | 5/02/11 18:40 | Intermittent data affected by environmental conditions - wind speed spike | WS, WD, Sigma | DD | 9/03/2011 |
| 7/02/11 10:20 | 22/02/11 13:15 | Intermittent additional automatic calibration checks | CO | DD | 9/03/2011 |
| 12/02/11 01:50 | 15/02/11 00:55 | Span out of tolerance | NO, NO ₂ , NO _x | DD | 9/03/2011 |
| 16/02/11 10:40 | 16/02/11 11:35 | Scheduled maintenance - monthly | CO, NO, NO ₂ , NO _x | DD | 9/03/2011 |
| 19/02/11 22:00 | 19/02/11 22:00 | Power interruption | All channels | DD | 9/03/2011 |
| 19/02/11 22:05 | 19/02/11 22:05 | Instrument stabilisation following power interruption | CO | DD | 9/03/2011 |
| 19/02/11 22:05 | 19/02/11 22:35 | Instrument stabilisation following power interruption | PM ₁₀ | DD | 9/03/2011 |
| 19/02/11 22:05 | 19/02/11 22:50 | Instrument stabilisation following power interruption | PM _{2.5} | DD | 9/03/2011 |
| 25/02/11 07:25 | 25/02/11 07:25 | Power interruption | All channels | DD | 9/03/2011 |
| 25/02/11 07:30 | 25/02/11 07:30 | Instrument stabilisation following power interruption | CO | DD | 9/03/2011 |
| 25/02/11 07:30 | 25/02/11 08:00 | Instrument stabilisation following power interruption | PM _{2.5} | DD | 9/03/2011 |
| 25/02/11 07:30 | 25/02/11 08:05 | Instrument stabilisation following power interruption | PM _{2.5} | DD | 9/03/2011 |
| 28/02/11 21:10 | 28/02/11 21:10 | Power interruption | CO, NO, NO ₂ , NO _x , PM _{2.5} , PM ₁₀ | DD | 9/03/2011 |

Table 11: Chaim Crt Valid Data Exception Table (continued)

| | | | | | |
|----------------|----------------|---|-------------------|----|------------|
| 28/02/11 21:15 | 28/02/11 21:15 | Instrument stabilisation following power interruption | CO | DD | 9/03/2011 |
| 28/02/11 21:15 | 28/02/11 21:45 | Instrument stabilisation following power interruption | PM ₁₀ | DD | 9/03/2011 |
| 28/02/11 21:15 | 28/02/11 21:55 | Instrument stabilisation following power interruption | PM _{2.5} | DD | 9/03/2011 |
| 2/03/11 14:15 | 31/03/11 21:45 | Intermittent additional automatic calibration checks | CO | DD | 10/04/2011 |
| 5/03/11 22:15 | 5/03/11 22:15 | Power interruption | All channels | DD | 10/04/2011 |
| 5/03/11 22:20 | 5/03/11 22:20 | Instrument stabilisation following power interruption | CO | DD | 10/04/2011 |
| 5/03/11 22:20 | 5/03/11 22:50 | Instrument stabilisation following power interruption | PM ₁₀ | DD | 10/04/2011 |
| 5/03/11 22:20 | 5/03/11 23:05 | Instrument stabilisation following power interruption | PM _{2.5} | DD | 10/04/2011 |
| 13/03/11 18:35 | 17/03/11 09:15 | Intermittent data affected by environmental conditions - wind speed spike | WS, WD, Sigma | DD | 10/04/2011 |
| 16/03/11 01:25 | 16/03/11 01:25 | Power interruption | All channels | DD | 10/04/2011 |
| 16/03/11 01:30 | 16/03/11 02:00 | Instrument stabilisation following power interruption | PM ₁₀ | DD | 10/04/2011 |
| 16/03/11 01:30 | 16/03/11 02:10 | Instrument stabilisation following power interruption | PM _{2.5} | DD | 10/04/2011 |
| 16/03/11 01:30 | 16/03/11 13:40 | Instrument fault after power interruption | CO | DD | 10/04/2011 |
| 17/03/11 09:10 | 17/03/11 09:15 | Scheduled maintenance - monthly | WS, WD, Sigma | DD | 10/04/2011 |

Table 11: Chaim Crt Valid Data Exception Table (continued)

| | | | | | |
|----------------|----------------|---|-------------------|----|------------|
| 17/03/11 10:05 | 17/03/11 10:45 | Scheduled maintenance - monthly | AT, RH | DD | 10/04/2011 |
| 17/03/11 10:20 | 17/03/11 10:30 | Scheduled maintenance - monthly | SR | DD | 10/04/2011 |
| 21/03/11 02:05 | 21/03/11 02:05 | Power interruption | All channels | DD | 10/04/2011 |
| 21/03/11 02:10 | 21/03/11 02:10 | Instrument stabilisation following power interruption | CO | DD | 10/04/2011 |
| 21/03/11 02:10 | 21/03/11 02:40 | Instrument stabilisation following power interruption | PM ₁₀ | DD | 10/04/2011 |
| 21/03/11 02:10 | 21/03/11 02:50 | Instrument stabilisation following power interruption | PM _{2.5} | DD | 10/04/2011 |

Table 12: Craig Rd Valid Data Exception

| Start Date | End Date | Reason | Change Details | User Name | Change Date |
|----------------|----------------|---|---|-----------|-------------|
| 6/01/11 05:50 | 30/01/11 05:45 | Data affected intermittently by environmental conditions - wind speed spike | WS, WD, Sigma | DD | 21/01/2011 |
| 16/01/11 01:50 | 18/01/11 13:35 | Instrument span out of tolerance | NO, NO ₂ , NO _x | DD | 21/01/2011 |
| 18/01/11 13:40 | 18/01/11 16:30 | Scheduled maintenance - monthly | CO, NO, NO ₂ , NO _x | DD | 21/01/2011 |
| 18/01/11 14:00 | 18/01/11 17:20 | Maintenance - TEOM filter change and instrument stabilisation | PM ₁₀ | DD | 21/01/2011 |
| 18/01/11 15:30 | 18/01/11 16:05 | Data transmission error due to maintenance | WS, WD, Sigma, AT, RH | DD | 21/01/2011 |
| 5/02/11 08:45 | 28/02/11 18:40 | Data affected intermittently by environmental conditions - wind speed spike | WS, WD, Sigma | DD | 9/03/2011 |
| 18/02/11 10:30 | 18/02/11 11:05 | Scheduled maintenance - monthly | CO, NO, NO ₂ , NO _x | DD | 9/03/2011 |
| 18/02/11 10:30 | 18/02/11 11:20 | Scheduled maintenance - monthly | CO | DD | 9/03/2011 |
| 19/02/11 22:00 | 19/02/11 22:00 | Power interruption | All channels | DD | 9/03/2011 |
| 19/02/11 22:05 | 19/02/11 22:10 | Instrument stabilisation following power interruption | CO | DD | 9/03/2011 |
| 19/02/11 22:05 | 19/02/11 22:35 | Instrument stabilisation following power interruption | PM ₁₀ | DD | 9/03/2011 |
| 25/02/11 07:25 | 25/02/11 07:25 | Power interruption | All channels | DD | 9/03/2011 |

Table 12: Craig Rd Valid Data Exception Table (continued)

| | | | | | |
|----------------|----------------|---|------------------|----|------------|
| 25/02/11 07:30 | 25/02/11 07:35 | Instrument stabilisation following power interruption | CO | DD | 9/03/2011 |
| 25/02/11 07:30 | 25/02/11 08:00 | Instrument stabilisation following power interruption | PM ₁₀ | DD | 9/03/2011 |
| 28/02/11 21:10 | 28/02/11 21:10 | Power interruption | All channels | DD | 9/03/2011 |
| 28/02/11 21:15 | 28/02/11 21:45 | Instrument stabilisation following power interruption | PM ₁₀ | DD | 9/03/2011 |
| 28/02/11 21:15 | 28/02/11 21:55 | Instrument stabilisation following power interruption | CO | DD | 9/03/2011 |
| 1/03/11 05:45 | 31/03/11 06:10 | Data affected intermittently by environmental conditions - wind speed spike | WS, WD, Sigma | DD | 10/04/2011 |
| 5/03/11 22:15 | 5/03/11 22:15 | Power interruption | All channels | DD | 10/04/2011 |
| 5/03/11 22:20 | 5/03/11 22:25 | Instrument stabilisation following power interruption | CO | DD | 10/04/2011 |
| 5/03/11 22:20 | 5/03/11 22:50 | Instrument stabilisation following power interruption | PM ₁₀ | DD | 10/04/2011 |
| 7/03/11 01:50 | 9/03/11 10:35 | Power interruption | All channels | DD | 10/04/2011 |
| 16/03/11 01:25 | 16/03/11 01:25 | Power interruption | All channels | DD | 10/04/2011 |
| 16/03/11 01:30 | 16/03/11 02:00 | Instrument stabilisation following power interruption | PM ₁₀ | DD | 10/04/2011 |
| 16/03/11 01:30 | 16/03/11 23:45 | Instrument stabilisation following power interruption | CO | DD | 10/04/2011 |
| 21/03/11 02:05 | 21/03/11 02:05 | Power interruption | All channels | DD | 10/04/2011 |

Table 12: Craig Rd Valid Data Exception Table (continued)

| | | | | | |
|----------------|----------------|---|---|----|------------|
| 21/03/11 02:10 | 21/03/11 02:15 | Instrument stabilisation following power interruption | CO | DD | 10/04/2011 |
| 21/03/11 02:10 | 21/03/11 02:40 | Instrument stabilisation following power interruption | PM ₁₀ | DD | 10/04/2011 |
| 28/03/11 12:00 | 28/03/11 14:40 | Scheduled maintenance - monthly | CO, NO, NO ₂ , NO _x | DD | 10/04/2011 |
| 28/03/11 13:35 | 28/03/11 13:40 | Scheduled maintenance - monthly | WS, WD, Sigma | DD | 10/04/2011 |
| 28/03/11 14:20 | 28/03/11 14:50 | Scheduled maintenance - monthly | AT, RH | DD | 10/04/2011 |

Table 13: Heads Rd Valid Data Exception Table

| Start Date | End Date | Reason | Change Details | User Name | Change Date |
|----------------|----------------|---|--|-----------|-------------|
| 8/01/11 21:30 | 10/01/11 12:50 | Power conditioner off | CO, NO, NO ₂ , NO _x , AT, RH, WS, WD, Sigma | DD | 21/01/2010 |
| 10/01/11 12:55 | 10/01/11 13:45 | Maintenance | CO, NO, NO ₂ , NO _x , WS, WD, Sigma | DD | 21/01/2010 |
| 13/01/11 15:10 | 14/01/11 14:55 | Instrument flow fault | PM ₁₀ | DD | 21/01/2010 |
| 14/01/11 15:00 | 18/01/11 12:20 | Instrument removed for repair | PM ₁₀ | DD | 21/01/2010 |
| 15/01/11 19:50 | 30/01/11 06:15 | Data affected intermittently by environmental conditions - wind speed spike | WS, WD, Sigma | DD | 21/01/2010 |
| 18/01/11 09:10 | 18/01/11 12:35 | Maintenance - calibration | CO, NO, NO ₂ , NO _x | DD | 21/01/2010 |
| 18/01/11 12:25 | 18/01/11 12:25 | Data transmission error due to maintenance | WS, WD, Sigma, AT, RH | DD | 21/01/2010 |
| 18/01/11 12:30 | 18/01/11 14:20 | Maintenance - installed instrument and performed calibration | PM ₁₀ | DD | 21/01/2010 |
| 22/01/11 01:50 | 25/01/11 10:50 | Instrument span out of tolerance | CO | DD | 21/01/2010 |
| 25/01/11 10:55 | 25/01/11 11:15 | Remote calibration | CO, NO, NO ₂ , NO _x | DD | 21/01/2010 |
| 3/02/11 12:25 | 26/02/11 07:00 | Data affected intermittently by environmental conditions - wind speed spike | WS, WD, Sigma | DD | 9/03/2011 |
| 11/02/11 01:50 | 13/02/11 00:55 | Instrument span out of tolerance | NO, NO ₂ , NO _x | DD | 9/03/2011 |

Table 13: Heads Rd Valid Data Exception Table (continued)

| | | | | | |
|----------------|----------------|---|---|----|------------|
| 15/02/11 21:50 | 15/02/11 21:50 | Power interruption | All channels | DD | 9/03/2011 |
| 15/02/11 21:55 | 15/02/11 22:00 | Instrument stabilisation following power interruption | CO, PM10 | DD | 9/03/2011 |
| 16/02/11 06:05 | 16/02/11 06:10 | Power interruption | All channels | DD | 9/03/2011 |
| 16/02/11 06:15 | 16/02/11 06:20 | Instrument stabilisation following power interruption | CO, PM ₁₀ | DD | 9/03/2011 |
| 16/02/11 12:30 | 16/02/11 13:55 | Scheduled maintenance - monthly | CO, NO, NO ₂ , NO _x | DD | 9/03/2011 |
| 1/03/11 06:10 | 30/03/11 08:00 | Data affected intermittently by environmental conditions - wind speed spike | WS, WD, Sigma | DD | 10/04/2011 |
| 16/03/11 07:05 | 16/03/11 14:30 | Power interruption | All channels | DD | 10/04/2011 |
| 16/03/11 14:35 | 16/03/11 15:00 | Instrument stabilisation following power interruption | NO, NO ₂ , NO _x | DD | 10/04/2011 |
| 16/03/11 14:35 | 16/03/11 15:05 | Instrument stabilisation following power interruption | PM ₁₀ | DD | 10/04/2011 |
| 16/03/11 14:35 | 17/03/11 11:20 | Instrument fault following power interruption | CO | DD | 10/04/2011 |
| 17/03/11 11:25 | 17/03/11 15:20 | Scheduled maintenance - monthly | NO, NO ₂ , NO _x | DD | 10/04/2011 |
| 17/03/11 11:25 | 17/03/11 15:25 | Scheduled maintenance - monthly | CO | DD | 10/04/2011 |
| 17/03/11 12:05 | 17/03/11 13:25 | Scheduled maintenance - monthly | WS, WD, Sigma | DD | 10/04/2011 |
| 17/03/11 13:10 | 17/03/11 13:10 | Scheduled maintenance - monthly | All channels | DD | 10/04/2011 |
| 17/03/11 13:50 | 17/03/11 14:15 | Scheduled maintenance - monthly | AT, RH | DD | 10/04/2011 |

Table 13: Heads Rd Valid Data Exception Table (continued)

| | | | | | |
|----------------|----------------|----------------------------------|---|----|------------|
| 29/03/11 01:50 | 30/03/11 10:00 | Instrument span out of tolerance | CO, NO, NO ₂ , NO _x | DD | 10/04/2011 |
| 30/03/11 10:05 | 30/03/11 10:25 | Maintenance - calibration | CO, NO, NO ₂ , NO _x | DD | 10/04/2011 |

8.0 Discussion

- Percentage availability for all parameters at Chaim Crt, except oxides of nitrogen and PM_{2.5}, was above 95% for the reporting period. The percentage availability for oxides of nitrogen was low, at 84%, due to a combination of power interruptions and the overnight spans being out of tolerance occasionally. The percentage availability for PM_{2.5} was low, at 94%, due to a combination of instrument drier faults and power interruptions.
- Percentage availability for all parameters at the Craig Rd station, except oxides of nitrogen and CO, was above 95% for the reporting period. The percentage availability for oxides of nitrogen was low, at 91%, due to a combination of power interruptions and the overnight spans being out of tolerance occasionally. The percentage availability for CO was low, at 92%, due to frequent power interruptions.
- Percentage availability for meteorological parameters at Head Rd were above 95%, while oxides of nitrogen, CO and PM₁₀ which fell below 95%. This was due to a combination of instrument faults, the overnight spans being out of tolerance and power interruption.
- There were no recorded readings over the MARP intervention levels for the reporting period.

-----END OF REPORT-----

Appendix 1

Definitions

NO: Nitric oxide

NO₂: Nitrogen dioxide

NO_x: Oxides of nitrogen

CO: Carbon monoxide

PM₁₀: Particulate less than 10 microns

PM_{2.5}: Particulate less than 2.5 microns

PM_{2.5_B}: PM_{2.5} base mass (without volatiles)

PM_{2.5_R}: PM_{2.5} with volatiles

WS: Wind Speed

WD: Wind Direction

AT: Ambient Temperature

RH: Relative Humidity

SR: Solar Radiation

ppb: Parts per billion

ppm: Parts per million

µg/m³: micrograms per cubic metre @ standard temperature and pressure (0°C and 101.3 kPa)

m/s: metres per second

deg: degrees (True North)

W/m²: Watts per square metre

Appendix 2

Explanation of Exception Table

Logger update and site integration refers to the initial handover and setup time of the instrument when it is first installed and the channels are stabilizing.

Data transmission error refers to a period of time when the instrument could not transmit data. This may be due to interference, or a problem with the phone line or modem.

Instrument fault refers to a period of time when the instrument was not in the normal operating mode and did not measure a representative value of the existing conditions.

Instrument out of service refers to a lack of data due to an instrument being shut down for repair, maintenance or factory calibration.

Maintenance refers to a period of time when the logger / instrument was switched off due to maintenance.

Power Interruption refers to no power to the station, therefore no data was collected at this time