

#### **REPORT**

## EastLink Ventilation Stack Emission Monitoring Report April - June 2019

Submitted to:

#### **Broadspectrum Pty Ltd**

EastLink Operations Centre 2 Hillcrest Avenue Ringwood VIC 3134

Submitted by:

## **Golder Associates Pty Ltd**

Building 7, Botanicca Corporate Park 570 – 588 Swan Street Richmond, Victoria 3121 Australia

+61 3 8862 3500

July 2019

097613024-070-R-Rev0



Accreditation No. 1910

Accredited for compliance with ISO/IEC 17025 - Testing

The results of the tests, calibrations and/or measurements included in

this document are traceable to Australian / national standards

# **Distribution List**

Electronic Copy - Broadspectrum

Electronic Copy - Golder Associates Pty. Ltd.



i

## Record of Issue

Company	Client Contact	Version	Date Issued	Method of Delivery	
Broadspectrum Pty Ltd, EastLink Operations Centre 2 Hillcrest Avenue Ringwood VIC 3134	Ms. Alex Monson	Revision A	19/07/2019	Electronic	
Broadspectrum Pty Ltd, EastLink Operations Centre 2 Hillcrest Avenue Ringwood VIC 3134	Ms. Alex Monson	Revision 0	24/07/2019	Electronic	

# **Table of Contents**

1.0	INTRO	DDUCTION	1
2.0	DISCI	ARGES TO AIR	2
3.0	VENT	ILATION STACK MONITORING PARAMETERS	3
4.0	METH	ODS	4
	4.1	PM <sub>2.5</sub>	4
	4.2	PM <sub>10</sub>	4
	4.3	Carbon Monoxide	4
	4.4	Oxides of Nitrogen	4
	4.5	Stack Velocity	5
5.0	MEAS	UREMENT UNCERTAINTY	5
6.0	VENT	ILATION STACK EMISSION MONITORING PERIOD: 01/04/2019 – 30/04/2019	6
	6.1	Data Capture	6
	6.2	Results	6
	6.2.1	PM <sub>2.5</sub>	6
	6.2.2	PM <sub>10</sub>	7
	6.2.3	Carbon Monoxide	8
	6.2.4	Oxides of Nitrogen	9
	6.2.4.1	Nitric Oxide	9
	6.2.4.2	Nitrogen Dioxide	10
	6.2.5	Stack Velocity	11
	6.3	Data Validation and Exceptions	12
7.0	VENT	ILATION STACK EMISSION MONITORING PERIOD: 01/05/2019 – 31/05/2019	14
	7.1	Data Capture	14
	7.2	Results	14
	7.2.1	PM <sub>2.5</sub>	14
	7.2.2	PM <sub>10</sub>	15
	7.2.3	Carbon Monoxide	16
	7.2.4	Oxides of Nitrogen	17
	7.2.4.1	Nitric Oxide	17



	7.2.4.2	Nitrogen Dioxide	18
	7.2.5	Stack Velocity	19
	7.3	Data Validation and Exceptions	20
8.0	VENT	ILATION STACK EMISSION MONITORING PERIOD: 01/06/2019 – 30/06/2019	23
	8.1	Data Capture	23
	8.2	Results	23
	8.2.1	PM <sub>2.5</sub>	23
	8.2.2	PM <sub>10</sub>	24
	8.2.3	Carbon Monoxide	25
	8.2.4	Oxides of Nitrogen	26
	8.2.4.	Nitric Oxide	26
	8.2.4.2	Nitrogen Dioxide	27
	8.2.5	Stack Velocity	28
	8.3	Data Validation and Exceptions	1
9.0	DISC	JSSION	3
	9.1	Comparison with Licence Limits	3
	9.2	Data Capture Year to Date	3
	1.1	Bubble Licence	4
TAE	SLES		
		scharges to Air	2
Tab	e 2: Me	asurement Uncertainty	5
Tab	le 3: Da	ta Capture Statistics - 1 Hour Averages	6
Tab	e 4: PN	1 <sub>2.5</sub> Mass Rate Percentiles (1 Hour Average)	6
Tab	e 5: PN	1 <sub>10</sub> Mass Rate Percentiles (1 Hour Average)	7
Tab	le 6: Ca	rbon Monoxide Mass Rate Percentiles (1 Hour Average)	8
Tab	e 7: Nit	ric Oxide Mass Rate Percentiles (1 Hour Average)	9
		rogen Dioxide Mass Rate Percentiles (1 Hour Average)	
		ta Exceptions - Eastern Ventilation Stack: April 2019	
		ata Exceptions - Western Ventilation Stack: April 2019	
		ata Capture Statistics - 1 Hour Averages	
		M <sub>2.5</sub> Mass Rate Percentiles (1 Hour Average)	
ıab	e 13: P	M <sub>10</sub> Mass Rate Percentiles (1 Hour Average)	15



Table 14: Carbon Monoxide Mass Rate Percentiles (1 Hour Average)	16
Table 15: Nitric Oxide Mass Rate Percentiles (1 Hour Average)	17
Table 16: Nitrogen Dioxide Mass Rate Percentiles (1 Hour Average)	18
Table 17: Data Exceptions - Eastern Ventilation Stack: May 2019	20
Table 18: Data Exceptions - Western Ventilation Stack: May 2019	21
Table 19: Data Capture Statistics - 1 Hour Averages	23
Table 20: PM <sub>2.5</sub> Mass Rate Percentiles (1 Hour Average)	23
Table 21: PM <sub>10</sub> Mass Rate Percentiles (1 Hour Average)	24
Table 22: Carbon Monoxide Mass Rate Percentiles (1 Hour Average)	25
Table 23: Nitric Oxide Mass Rate Percentiles (1 Hour Average)	26
Table 24: Nitrogen Dioxide Mass Rate Percentiles (1 Hour Average)	27
Table 25: Data Exceptions - Eastern Ventilation Stack: June 2018	1
Table 26: Data Exceptions - Western Ventilation Stack: June 2018	1
Table 27: Maximum (1 Hour Average) Mass Rate (01/04/2019 - 30/06/2019)	3
Table 28: Data Capture Year to Date (%)	4
Table 29: Ventilation Stack Emissions 1/07/2018 – 30/06/2019 (tonnes/year)	4
FIGURES	
Figure 1: Ventilation Stack Locations	2
Figure 2: PM <sub>2.5</sub> Mass Rate (1 Hour Average)	7
Figure 3: PM <sub>10</sub> Mass Rate (1 Hour Average)	8
Figure 4: Carbon Monoxide Mass Rate (1 Hour Average)	9
Figure 5: Nitric Oxide Mass Rate (1 Hour Average)	10
Figure 6: Nitrogen Dioxide Mass Rate (1 Hour Average)	11
Figure 7: Stack Velocity (1 Hour Average)	11
Figure 8: PM <sub>2.5</sub> Mass Rate (1 Hour Average)	15
Figure 9: PM <sub>10</sub> Mass Rate (1 Hour Average)	16
Figure 10: Carbon Monoxide Mass Rate (1 Hour Average)	17
Figure 11: Nitric Oxide Mass Rate (1 Hour Average)	18
Figure 12: Nitrogen Dioxide Mass Rate (1 Hour Average)	19
Figure 13: Stack Velocity (1 Hour Average)	19
Figure 14: PM <sub>2.5</sub> Mass Rate (1 Hour Average)	24
Figure 15: PM <sub>10</sub> Mass Rate (1 Hour Average)	25
Figure 16: Carbon Monoxide Mass Rate (1 Hour Average)	26
Figure 17: Nitrie Ovide Mana Rate (1 Haur Average)	^7
Figure 17: Nitric Oxide Mass Rate (1 Hour Average)	27



Figure 18: Nitrogen Dioxide Mass Rate (1 Hour Average)	28
Figure 19: Stack Velocity (1 Hour Average)	28
Figure 20: Ventilation Stack Emissions as Percentage of Licence Limit (1/07/2018 – 30/06/2019)	4
The corresponding bubble limits for uncorrected PM <sub>2.5</sub> and PM <sub>10</sub> TEOM data are:	5

#### **APPENDICES**

#### **APPENDIX A**

Important Information Relating to this Report



#### 1.0 INTRODUCTION

EastLink is a 39 kilometre motorway running between Donvale in Melbourne's north-east to Frankston in Melbourne's south-east with two tunnels under the Mullum Mullum Valley. Broadspectrum Pty Ltd, who are responsible for operation and maintenance of the road, commissioned Golder Associates Pty. Ltd. to provide continuous emission monitoring services for the EastLink motorway project. The services provided include:

- Operations and maintenance services for the EastLink ventilation stack continuous emission monitoring systems (CEMS)
- NATA endorsed emission monitoring reports.

Monitoring commenced on the 29<sup>th</sup> June, 2008 with the opening of the EastLink motorway. Results for the sampling period 1<sup>st</sup> April, 2019 to 30<sup>th</sup> June, 2019 inclusive are contained in the following report.

The work was conducted under the following Broadspectrum Pty Ltd Work Order numbers:

Month	Western Stack	Eastern Stack
April	1107518	1107306
May	1112675	1112351
June	1117009	1116530

Your attention is drawn to the document - "Important Information Relating to this Report" (LEG04, RL2), which is included in Appendix A of this report. The statements presented in this document are intended to advise you of what your realistic expectations of this report should be. The document is not intended to reduce the level of responsibility accepted by Golder, but rather to ensure that all parties who may rely on this report are aware of the responsibilities each assumes in so doing. We would be pleased to answer any questions the reader may have regarding this document.



## 2.0 DISCHARGES TO AIR

EastLink has discharges to air servicing two road tunnels. Discharge Point No. 1 (DP1) services the inbound (Melba) tunnel and Discharge Point No. 2 (DP2) services the outbound (Mullum Mullum) tunnel.

The locations of the discharges to air are described in Table 1 and presented in Figure 1.

Table 1: Discharges to Air

Discharge Point No.	Station Name	Location			
1	Western ventilation stack	Western end of inbound tunnel (Melba) - Donvale			
2	Eastern ventilation stack	Eastern end of outbound tunnel (Mullum Mullum) – Ringwood			

Monitoring equipment is housed in temperature controlled cabinets located at the base of each of the ventilation stacks. Particulate matter and gaseous sample inlets are installed inside the plenum chamber of each of the ventilation stacks.



Figure 1: Ventilation Stack Locations

#### 3.0 VENTILATION STACK MONITORING PARAMETERS

The following parameters are monitored continuously, with averages logged at 5 minute intervals:

- Particulate matter with an equivalent aerodynamic diameter less than 2.5 microns (PM<sub>2.5</sub>)
- Particulate matter with an equivalent aerodynamic diameter less than 10 microns (PM<sub>10</sub>)
- Total oxides of nitrogen (NO<sub>x</sub>)
- Nitric oxide (NO)
- Nitrogen dioxide (NO<sub>2</sub>)
- Carbon monoxide (CO)
- Stack velocity
- Stack temperature
- Ambient pressure.



#### 4.0 METHODS

#### 4.1 $PM_{2.5}$

PM<sub>2.5</sub> concentrations in the tunnel ventilation stacks are determined using 1400 Series Tapered Element Oscillating Microbalance (TEOM) analysers. Sample inlets are located inside the plenum chamber of each ventilation stack.

Exhaust gas is drawn through a  $PM_{2.5}$  size selective inlet ( $PM_{10}$  WINS head fitted with a  $PM_{2.5}$  sharp cut cyclone (SCC)) at 1 m<sup>3</sup>/h. The flow is then isokinetically split into two streams; 1 l/min stream which passes through the filter on the mass transducer and a 15.7 l/min bypass stream.

The sample stream is heated to 50°C to maintain a low and therefore relatively constant humidity.

Measurements are made in real-time (2 s intervals) with the 5 minute averages logged. 1 hour averages are then calculated from the logged data.

The PM<sub>2.5</sub> monitoring method is based on the requirements of Australian Standard AS 3580.9.13, "Methods for Sampling and Analysis of Ambient Air: Determination of Suspended Particulate Matter – PM<sub>2.5</sub> Continuous Direct Mass Method Using a Tapered Element Oscillating Microbalance Monitor".

#### 4.2 PM<sub>10</sub>

PM<sub>10</sub> concentrations in the tunnel ventilation stacks are determined using 1400 Series Tapered Element Oscillating Microbalance (TEOM) analysers. Sample inlets are located inside the plenum chamber of each ventilation stack.

Exhaust gas is drawn through a  $PM_{10}$  size selective inlet ( $PM_{10}$  WINS head) at 1 m<sup>3</sup>/h. The flow is then isokinetically split into two streams; 1 l/min stream which passes through the filter on the mass transducer and a 15.7 l/min bypass stream.

The sample stream is heated to 50°C to maintain a low and therefore relatively constant humidity.

Measurements are made in real-time (2 s intervals) with the 5 minute averages logged. 1 hour averages are then calculated from the logged data.

The PM<sub>10</sub> monitoring method is based on the requirements of Australian Standard AS 3580.9.8, "Methods for Sampling and Analysis of Ambient Air: Determination of Suspended Particulate Matter – PM<sub>10</sub> Continuous Direct Mass Method Using a Tapered Element Oscillating Microbalance Analyser".

#### 4.3 Carbon Monoxide

Carbon monoxide concentrations in the tunnel ventilation stacks are determined by infra-red gas filter correlation analysers.

Automatic calibrations are carried out daily against a NATA certified reference gas mixture. Manual calibrations are conducted at one month intervals.

The carbon monoxide monitoring method is based on the requirements of Australian Standard AS 3580.7.1, "Determination of Carbon Monoxide – Direct Reading Instrumental Method".

## 4.4 Oxides of Nitrogen

Oxides of nitrogen concentrations in the tunnel ventilation stacks are determined by chemiluminescence gas analysers.



Automatic calibrations are carried out daily against a NATA certified reference gas mixture. Manual calibrations are conducted at one month intervals.

The oxides of nitrogen (NO, NO<sub>2</sub> and NO<sub>x</sub>) monitoring method is based on the requirements of Australian Standard AS 3580.5.1, "Determination of Oxides of Nitrogen – Chemiluminescence Method".

## 4.5 Stack Velocity

Stack gas velocity was determined using an optical flow sensor that complies with USEPA Code of Federal Regulations (CFR 40) Part 75, "Continuous Emission Monitoring" requirements.

#### 5.0 MEASUREMENT UNCERTAINTY

**Table 2: Measurement Uncertainty** 

Parameter	Method	Estimated Uncertainty		
PM <sub>10</sub>	TEOM	± 5%		
PM <sub>2.5</sub>	TEOM	± 5%		
NO, NO <sub>2</sub> , NO <sub>X</sub>	Chemiluminescence	± 10%		
со	Infra-red gas filter correlation	± 10%		
Stack velocity	Optical flow sensor	± 0.1 m/s or 5% of reading, whichever is greater		
Ambient temperature Thermocouple (TEOM)		± 2°C		
Ambient pressure TEOM pressure transducer		± 1.5%		



# 6.0 VENTILATION STACK EMISSION MONITORING PERIOD: 01/04/2019 – 30/04/2019

## 6.1 Data Capture

Data capture is defined as the number of valid data periods collected divided by the number of available data periods. Valid data excludes periods where the instrument is unavailable due to calibration and maintenance and excludes periods where the data has been rejected due to quality assurance/data validation procedures.

The data capture statistics for the reporting period 1<sup>st</sup> April to 30<sup>th</sup> April, 2019 are shown in Table 3. Averages were only collected for those periods where the 5 minute data constituted 75% data capture. Reduced data capture for NO<sub>x</sub> eastern ventilation system was due to analyser span drift out of tolerance.

Section 6.3 provides further information on the reasons for invalid data periods.

**Table 3: Data Capture Statistics - 1 Hour Averages** 

Paramet er	Station	Collected Periods	Available Periods	Data Capture	
PM <sub>2.5</sub>	Eastern	718	720	99.7%	
	Western	718	720	99.7%	
PM <sub>10</sub>	Eastern	714	720	99.2%	
	Western	718	720	99.7%	
NO, NO <sub>2</sub>	Eastern	Eastern 649 720		90.1%	
	Western	673	720	93.5%	
со	Eastern	686	720	95.3%	
	Western	686	720	95.3%	

#### 6.2 Results

#### 6.2.1 PM<sub>2.5</sub>

 $PM_{2.5}$  (1 hour average) mass rate of emission statistics for the reporting period are given in Table 4. A plot of  $PM_{2.5}$  (1 hour average) mass rate of emission for the reporting period is presented in Figure 2.

Table 4: PM<sub>2.5</sub> Mass Rate Percentiles (1 Hour Average)

Station	PM <sub>2.5</sub> Mass Rate (kg/h) (1 Hour Average)							
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>	
Eastern	0.18	0.14	0.12	0.10	0.080	0.057	0.025	
Western	0.17	0.15	0.13	0.11	0.080	0.048	0.023	






Figure 2: PM<sub>2.5</sub> Mass Rate (1 Hour Average)

#### 6.2.2 PM<sub>10</sub>

 $PM_{10}$  (1 hour average) mass rate of emission statistics for the reporting period are given in Table 5. A plot of  $PM_{10}$  (1 hour average) mass rate of emission for the reporting period is presented in Figure 3.

Table 5: PM<sub>10</sub> Mass Rate Percentiles (1 Hour Average)

Station	PM₁₀ Mass Rate (kg/h) (1 Hour Average)							
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>	
Eastern	0.44	0.23	0.19	0.16	0.13	0.089	0.048	
Western	0.51	0.28	0.25	0.21	0.14	0.086	0.050	




Figure 3: PM<sub>10</sub> Mass Rate (1 Hour Average)

#### 6.2.3 Carbon Monoxide

Carbon monoxide (1 hour average) mass rate of emission statistics for the reporting period are given in Table 6. A plot of carbon monoxide (1 hour average) mass rate of emission for the reporting period is presented in Figure 4.

Table 6: Carbon Monoxide Mass Rate Percentiles (1 Hour Average)

Station	Carbon Monoxide Mass Rate (kg/h) (1 Hour Average)							
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>	
Eastern	10	7.4	6.6	5.5	4.2	3.2	2.4	
Western	9.4	8.5	7.4	6.1	4.8	3.4	2.5	




Figure 4: Carbon Monoxide Mass Rate (1 Hour Average)

## 6.2.4 Oxides of Nitrogen

#### 6.2.4.1 Nitric Oxide

Nitric oxide (1 hour average) mass rate of emission statistics for the reporting period are given in Table 7. A plot of nitric oxide (1 hour average) mass rate of emission for the reporting period is presented in Figure 5.

**Table 7: Nitric Oxide Mass Rate Percentiles (1 Hour Average)** 

Station	Nitric Oxide Mass Rate (kg/h) (1 Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	3.5	2.6	2.5	2.0	1.7	1.2	0.52
Western	4.3	3.3	3.1	2.2	1.8	1.1	0.54




Figure 5: Nitric Oxide Mass Rate (1 Hour Average)

#### 6.2.4.2 Nitrogen Dioxide

Nitrogen dioxide (1 hour average) mass rate of emission statistics for the reporting period are given in Table 8. A plot of nitrogen dioxide (1 hour average) mass rate of emission for the reporting period is presented in Figure 6.

Table 8: Nitrogen Dioxide Mass Rate Percentiles (1 Hour Average)

Station	Ni	Nitrogen Dioxide Mass Rate (kg/h) (1 Hour Average)					
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	0.90	0.67	0.58	0.46	0.36	0.23	0.12
Western	0.77	0.59	0.52	0.40	0.30	0.20	0.13




Figure 6: Nitrogen Dioxide Mass Rate (1 Hour Average)

## 6.2.5 Stack Velocity

The stack velocity (1 hour average) plot for the reporting period is presented in Figure 7.




Figure 7: Stack Velocity (1 Hour Average)

## 6.3 Data Validation and Exceptions

Data contained in the report has been validated against performance and calibration requirements for each instrument. Data during maintenance and calibration periods has been removed from the validated data sets. Tables 9 and 10 list the data exceptions for the eastern and western ventilation stacks, where valid data is less than 75% of the one hour average. Data during automatic calibrations of the gaseous atmospheric contaminants has also been removed from the data sets.

Table 9: Data Exceptions - Eastern Ventilation Stack: April 2019

Start	End	Parameter	Reason
1/04/2019 11:55	1/04/2019 12:00	PM <sub>10</sub>	Invalid <sup>1</sup>
2/04/2019 10:20	2/04/2019 10:25	PM <sub>10</sub>	Invalid <sup>1</sup>
3/04/2019 9:30	3/04/2019 10:35	PM <sub>2.5</sub>	Maintenance / calibration
3/04/2019 09:45	3/04/2019 10:15	PM <sub>10</sub>	Maintenance / calibration
4/04/2019 10:15	4/04/2019 12:20	CO, NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance / calibration
5/04/2019 01:00	5/04/2019 01:50	PM <sub>10</sub>	Invalid <sup>1</sup>
5/04/2019 12:05	5/04/2019 13:10	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance / calibration
11/04/2019 03:05	11/04/2019 03:20	PM <sub>10</sub>	Invalid <sup>1</sup>
13/04/2019 19:35	13/04/2019 19:45	PM <sub>10</sub>	Invalid <sup>1</sup>
13/04/2019 22:35	13/04/2019 22:50	PM <sub>10</sub>	Invalid <sup>1</sup>
16/04/2019 10:10	16/04/2019 10:50	со	Maintenance / calibration
21/04/2019 16:00	21/04/2019 16:20	PM <sub>10</sub>	Invalid <sup>1</sup>
23/04/2019 01:00	24/04/2019 15:10	NO, NO <sub>2</sub> , NO <sub>x</sub>	Invalid data - span drift
30/04/2019 08:55	30/04/2019 09:20	со	Maintenance / calibration

Notes: 1 – In the opinion of the reviewer

Table 10: Data Exceptions - Western Ventilation Stack: April 2019

Start	End	Parameter	Reason
3/04/2019 08:30	3/04/2019 09:40	PM <sub>2.5</sub>	Maintenance / calibration
3/04/2019 08:35	3/04/2019 09:55	PM <sub>10</sub>	Maintenance / calibration
3/04/2019 12:00	3/04/2019 12:45	со	Maintenance / calibration
4/04/2019 12:30	4/04/2019 13:45	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance / calibration
4/04/2019 12:30	4/04/2019 13:40	со	Maintenance / calibration
5/04/2019 13:40	5/04/2019 14:15	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance / calibration
8/04/2019 01:00	8/04/2019 13:30	NO, NO <sub>2</sub> , NO <sub>x</sub>	Invalid data - span drift
24/04/2019 13:45	24/04/2019 14:25	со	Maintenance / calibration

Notes: 1 – In the opinion of the reviewer

A number periods occurred where  $PM_{2.5}$  concentrations were greater than the corresponding  $PM_{10}$  concentrations. If no valid reason was found to exclude the data, the data was left unchanged in the data set. Examples of such occurrences are listed below:

- East Ventilation stack 14/04/2019 15:15 15:50
- East Ventilation stack 24/04/2019 14:20 15:00

# 7.0 VENTILATION STACK EMISSION MONITORING PERIOD: 01/05/2019 – 31/05/2019

## 7.1 Data Capture

Data capture is defined as the number of valid data periods collected divided by the number of available data periods. Valid data excludes periods where the instrument is unavailable due to calibration and maintenance and excludes periods where the data has been rejected due to quality assurance/data validation procedures.

The data capture statistics for the reporting period 1<sup>st</sup> May to 31st May, 2019 are shown in Table 11. Averages were only collected for those periods where the 5 minute data constituted 75% data capture. Reduced data capture for CO eastern ventilation system was due to analyser span drift out of tolerance (CO Auto-Gain Control Intensity was out of tolerance. The optic bench was recalibrated on 20/05/2019. Reduced data capture for NO<sub>x</sub> eastern ventilation system was due to *span drift out of tolerance* requiring replacement on 23/05/2019.

Section 7.3 provides further information on the reasons for invalid data periods.

Table 11: Data Capture Statistics - 1 Hour Averages

Parameter	Station	Collected Periods	Available Periods	Data Capture
PM <sub>2.5</sub>	Eastern	727	744	97.7%
	Western	741	744	99.6%
PM <sub>10</sub>	Eastern	741	744	99.6%
	Western	740	744	99.5%
NO, NO <sub>2</sub>	Eastern	638	744	85.8%
	Western	710	744	95.4%
СО	Eastern	605	744	81.3%
	Western	705	744	94.8%

#### 7.2 Results

#### 7.2.1 PM<sub>2.5</sub>

 $PM_{2.5}$  (1 hour average) mass rate of emission statistics for the reporting period are given in Table 12. A plot of  $PM_{2.5}$  (1 hour average) mass rate of emission for the reporting period is presented in Figure 8.

Table 12: PM<sub>2.5</sub> Mass Rate Percentiles (1 Hour Average)

Station	PM <sub>2.5</sub> Mass Rate (kg/h) (1 Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	0.21	0.15	0.14	0.11	0.071	0.057	0.024
Western	0.21	0.16	0.14	0.11	0.071	0.045	0.023






Figure 8: PM<sub>2.5</sub> Mass Rate (1 Hour Average)

#### 7.2.2 PM<sub>10</sub>

 $PM_{10}$  (1 hour average) mass rate of emission statistics for the reporting period are given in Table 13. A plot of  $PM_{10}$  (1 hour average) mass rate of emission for the reporting period is presented in Figure 9.

Table 13: PM<sub>10</sub> Mass Rate Percentiles (1 Hour Average)

Station	PM₁₀ Mass Rate (kg/h) (1 Hour Average)							
	Maximum	Maximum 99 <sup>th</sup> 98 <sup>th</sup> 95 <sup>th</sup> 90 <sup>th</sup> 75 <sup>th</sup> 50 <sup>th</sup>						
Eastern	0.56	0.27	0.25	0.16	0.13	0.090	0.044	
Western	0.37	0.27	0.24	0.18	0.13	0.077	0.047	




Figure 9: PM<sub>10</sub> Mass Rate (1 Hour Average)

#### 7.2.3 Carbon Monoxide

Carbon monoxide (1 hour average) mass rate of emission statistics for the reporting period are given in Table 14. A plot of carbon monoxide (1 hour average) mass rate of emission for the reporting period is presented in Figure 10.

Table 14: Carbon Monoxide Mass Rate Percentiles (1 Hour Average)

Station	Carbon Monoxide Mass Rate (kg/h) (1 Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	11	8.0	6.7	5.5	4.5	3.3	2.4
Western	13	8.2	7.7	6.8	5.1	3.5	2.7




Figure 10: Carbon Monoxide Mass Rate (1 Hour Average)

## 7.2.4 Oxides of Nitrogen

#### 7.2.4.1 Nitric Oxide

Nitric oxide (1 hour average) mass rate of emission statistics for the reporting period are given in Table 15. A plot of nitric oxide (1 hour average) mass rate of emission for the reporting period is presented in Figure 11.

Table 15: Nitric Oxide Mass Rate Percentiles (1 Hour Average)

Station	Nitric Oxide Mass Rate (kg/h) (1 Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	3.7	3.2	2.6	2.0	1.6	1.2	0.54
Western	4.3	3.8	3.5	2.4	1.8	1.2	0.63






Figure 11: Nitric Oxide Mass Rate (1 Hour Average)

#### 7.2.4.2 Nitrogen Dioxide

Nitrogen dioxide (1 hour average) mass rate of emission statistics for the reporting period are given in Table 16. A plot of nitrogen dioxide (1 hour average) mass rate of emission for the reporting period is presented in Figure 12.

Table 16: Nitrogen Dioxide Mass Rate Percentiles (1 Hour Average)

Station	Nitrogen Dioxide Mass Rate (kg/h) (1 Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	0.82	0.70	0.52	0.42	0.34	0.22	0.13
Western	0.81	0.63	0.58	0.42	0.29	0.21	0.13




Figure 12: Nitrogen Dioxide Mass Rate (1 Hour Average)

## 7.2.5 Stack Velocity

The stack velocity (1 hour average) plot for the reporting period is presented in Figure 13.




Figure 13: Stack Velocity (1 Hour Average)

## 7.3 Data Validation and Exceptions

Data contained in the report has been validated against performance and calibration requirements for each instrument. Data during maintenance and calibration periods has been removed from the validated data sets. Tables 17 and 18 list the data exceptions for the eastern and western ventilation stacks, where valid data is less than 75% of the one hour average. Data during automatic calibrations of the gaseous atmospheric contaminants has also been removed from the data sets.

Table 17: Data Exceptions - Eastern Ventilation Stack: May 2019

Start	End	Parameter	Reason
11/05/2019 04:00	11/05/2019 05:20	PM <sub>2.5</sub>	Invalid <sup>1</sup>
11/05/2019 08:40	11/05/2019 09:40	PM <sub>2.5</sub>	Invalid <sup>1</sup>
12/05/2019 04:25	12/05/2019 04:50	PM <sub>10</sub>	Invalid <sup>1</sup>
12/05/2019 21:15	12/05/2019 22:55	PM <sub>2.5</sub>	Invalid <sup>1</sup>
13/05/2019 15:15	13/05/2019 16:25	со	Maintenance / calibration
16/05/2019 01:00	20/05/2019 23:15	со	Invalid data - span drift
17/05/2019 09:40	17/05/2019 11:35	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance / calibration
17/05/2019 11:45	17/05/2019 11:55	PM <sub>2.5</sub>	Invalid <sup>1</sup>
20/05/2019 11:20	20/05/2019 12:00	со	Maintenance / calibration
20/05/2019 12:10	20/05/2019 12:35	PM <sub>2.5</sub>	Maintenance / calibration
21/05/2019 3:00	21/05/2019 05:45	PM <sub>2.5</sub>	Invalid <sup>1</sup>
23/05/2019 15:15	23/05/2019 16:05	PM <sub>2.5</sub>	Invalid <sup>1</sup>
23/05/2019 15:20	24/05/2019 13:20	NO, NO <sub>2</sub> , NO <sub>x</sub>	Removed for repair
23/05/2019 22:05	23/05/2019 23:55	PM <sub>2.5</sub>	Invalid <sup>1</sup>
24/05/2019 11:00	24/05/2019 14:50	PM <sub>2.5</sub>	Maintenance / calibration
24/05/2019 11:45	24/05/2019 13:15	со	Maintenance / calibration
24/05/2019 13:45	24/05/2019 14:35	PM <sub>10</sub>	Maintenance / calibration
26/05/2019 00:40	27/05/2019 13:20	NO, NO <sub>2</sub> , NO <sub>x</sub>	Invalid data - span drift
26/05/2019 03:30	26/05/2019 04:10	PM <sub>10</sub>	Invalid <sup>1</sup>
27/05/2019 12:35	27/05/2019 13:00	со	Maintenance / calibration

**Note**: <sup>1</sup> – In the opinion of the reviewer.



Table 18: Data Exceptions - Western Ventilation Stack: May 2019

Start	End	Parameter	Reason
1/05/2019 14:35	1/05/2019 14:55	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance / calibration
10/05/2019 13:45	10/05/2019 14:35	со	Maintenance / calibration
13/05/2019 10:55	13/05/2019 11:35	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance / calibration
16/05/2019 14:45	16/05/2019 15:25	со	Maintenance / calibration
25/05/2019 12:00	25/05/2019 12:45	CO, NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance / calibration
25/05/2019 12:05	25/05/2019 13:30	PM <sub>2.5</sub>	Maintenance / calibration
25/05/2019 12:30	25/05/2019 15:20	PM <sub>10</sub>	Maintenance / calibration
25/05/2019 18:20	25/05/2019 18:40	PM <sub>2.5</sub>	Invalid <sup>1</sup>

**Note**: <sup>1</sup> – In the opinion of the reviewer.

A number of periods occurred where  $PM_{2.5}$  concentrations were greater than the corresponding  $PM_{10}$  concentrations. If no valid reason was found to exclude the data, the data was left unchanged in the data set. Examples of such occurrences are listed below:

- East Ventilation stack 14/05/2019 14:05 14:25
- East Ventilation stack 15/05/2019 06:45 07:05
- East Ventilation stack 17/05/2019 18:50 20:55
- West Ventilation stack 19/05/2019 12:35 20:20



# 8.0 VENTILATION STACK EMISSION MONITORING PERIOD: 01/06/2019 – 30/06/2019

## 8.1 Data Capture

Data capture is defined as the number of valid data periods collected divided by the number of available data periods. Valid data excludes periods where the instrument is unavailable due to calibration and maintenance and excludes periods where the data has been rejected due to quality assurance/data validation procedures.

The data capture statistics for the reporting period 1<sup>st</sup> June to 30<sup>th</sup> June, 2019 are shown in Table 19. Averages were only collected for those periods where the 5 minute data constituted 75% data capture.

Section 8.3 provides further information on the reasons for invalid data periods.

Table 19: Data Capture Statistics - 1 Hour Averages

Parameter	Station	Collected Periods	Available Periods	Data Capture	
DM	Eastern	718	720	99.7%	
PM <sub>2.5</sub>	Western	719	720	99.1%	
PM <sub>10</sub>	Eastern	713	720	99.0%	
F IVI10	Western	720	720	100%	
NO NO	Eastern	677	720	94.0%	
NO, NO <sub>2</sub>	Western	513	720	71.3%	
00	Eastern	681	720	94.6%	
CO	Western	688	720	95.6%	

#### 8.2 Results

#### 8.2.1 PM<sub>2.5</sub>

 $PM_{2.5}$  (1 hour average) mass rate of emission statistics for the reporting period are given in Table 20. A plot of  $PM_{2.5}$  (1 hour average) mass rate of emission for the reporting period is presented in Figure 14.

Table 20: PM<sub>2.5</sub> Mass Rate Percentiles (1 Hour Average)

Station	PM <sub>2.5</sub> Mass Rate (kg/h) (1 Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	0.11	0.10	0.089	0.077	0.054	0.048	0.021
Western	0.15	0.13	0.11	0.072	0.054	0.038	0.020






Figure 14: PM<sub>2.5</sub> Mass Rate (1 Hour Average)

#### 8.2.2 PM<sub>10</sub>

 $PM_{10}$  (1 hour average) mass rate of emission statistics for the reporting period are given in Table 21. A plot of  $PM_{10}$  (1 hour average) mass rate of emission for the reporting period is presented in Figure 15.

Table 21: PM<sub>10</sub> Mass Rate Percentiles (1 Hour Average)

Station	PM₁₀ Mass Rate (kg/h) (1 Hour Average)							
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>	
Eastern	0.25	0.18	0.16	0.14	0.11	0.079	0.035	
Western	0.41	0.27	0.24	0.16	0.13	0.088	0.040	




Figure 15: PM<sub>10</sub> Mass Rate (1 Hour Average)

#### 8.2.3 Carbon Monoxide

Carbon monoxide (1 hour average) mass rate of emission statistics for the reporting period are given in Table 22. A plot of carbon monoxide (1 hour average) mass rate of emission for the reporting period is presented in Figure 16.

Table 22: Carbon Monoxide Mass Rate Percentiles (1 Hour Average)

Station	Carbon Monoxide Mass Rate (kg/h) (1 Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	8.8	7.5	7.0	5.8	4.8	3.9	2.6
Western	10	7.2	6.5	5.1	4.0	3.0	2.3




Figure 16: Carbon Monoxide Mass Rate (1 Hour Average)

#### 8.2.4 Oxides of Nitrogen

#### 8.2.4.1 Nitric Oxide

Nitric oxide (1 hour average) mass rate of emission statistics for the reporting period are given in Table 23. A plot of nitric oxide (1 hour average) mass rate of emission for the reporting period is presented in Figure 17.

Table 23: Nitric Oxide Mass Rate Percentiles (1 Hour Average)

Station	Nitric Oxide Mass Rate (kg/h) (1 Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	1.9	1.6	1.5	1.4	1.2	0.95	0.35
Western	3.8	3.3	2.9	1.9	1.4	1.0	0.53






Figure 17: Nitric Oxide Mass Rate (1 Hour Average)

## 8.2.4.2 Nitrogen Dioxide

Nitrogen dioxide (1 hour average) mass rate of emission statistics for the reporting period are given in Table 24. A plot of nitrogen dioxide (1 hour average) mass rate of emission for the reporting period is presented in Figure 18.

Table 24: Nitrogen Dioxide Mass Rate Percentiles (1 Hour Average)

Station	Nitrogen Dioxide Mass Rate (kg/h) (1 Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	0.52	0.41	0.39	0.33	0.25	0.20	0.086
Western	0.66	0.55	0.50	0.30	0.23	0.17	0.096




Figure 18: Nitrogen Dioxide Mass Rate (1 Hour Average)

## 8.2.5 Stack Velocity

The stack velocity (1 hour average) plot for the reporting period is presented in Figure 19.




Figure 19: Stack Velocity (1 Hour Average)

## 8.3 Data Validation and Exceptions

Data contained in the report has been validated against performance and calibration requirements for each instrument. Data during maintenance and calibration periods has been removed from the validated data sets. Tables 25 and 26 list the data exceptions for the eastern and western ventilation stacks, where valid data is less than 75% of the one hour average. Data during automatic calibrations of the gaseous atmospheric contaminants has also been removed from the data sets.

Table 25: Data Exceptions - Eastern Ventilation Stack: June 2018

Start	End	Parameter	Reason
5/06/2019 12:20	5/06/2019 13:15	CO, NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance / calibration
11/06/2019 10:40	11/06/2019 11:15	CO, NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance / calibration
12/06/2019 12:10	12/06/2019 13:55	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance / calibration
12/06/2019 12:40	12/06/2019 13:45	со	Maintenance / calibration
13/06/2019 15:10	13/06/2019 15:10	со	Maintenance / calibration
20/06/2019 14:10	20/06/2019 15:20	CO, NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance / calibration
21/06/2019 03:25	21/06/2019 03:45	PM <sub>10</sub>	Invalid <sup>1</sup>
23/06/2019 04:45	23/06/2019 05:05	PM <sub>10</sub>	Invalid <sup>1</sup>
27/06/2019 10:25	27/06/2019 14:50	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance / calibration
27/06/2019 10:25	27/06/2019 13:10	со	Maintenance / calibration
27/06/2019 10:50	27/06/2019 11:45	PM <sub>2.5</sub>	Maintenance / calibration
29/06/2019 06:00	29/06/2019 06:15	PM <sub>10</sub>	Invalid <sup>1</sup>
29/06/2019 22:25	29/06/2019 22:35	PM <sub>10</sub>	Invalid <sup>1</sup>
30/06/2019 01:15	30/06/2019 05:35	PM <sub>10</sub>	Invalid <sup>1</sup>

**Note**: <sup>1</sup> – In the opinion of the reviewer.

Table 26: Data Exceptions - Western Ventilation Stack: June 2018

Start	End	Parameter	Reason
8/03/2018 22:50	8/03/2018 23:25	PM <sub>2.5</sub>	Invalid data <sup>1</sup>
9/03/2018 1:45	9/03/2018 2:25	PM <sub>2.5</sub>	Invalid data¹
9/03/2018 19:25	10/03/2018 8:35	PM <sub>2.5</sub>	Invalid data <sup>1</sup>
10/03/2018 10:00	10/03/2018 10:20	PM <sub>2.5</sub>	Invalid data¹



Start	End	Parameter	Reason
4/06/2019 01:00	5/06/2019 14:25	NO, NO <sub>2</sub> , NO <sub>x</sub>	Span drift out of tolerance
6/06/2019 17:20	6/06/2019 18:55	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance / calibration
11/06/2019 04:30	11/06/2019 04:50	PM <sub>2.5</sub>	Invalid <sup>1</sup>
12/06/2019 13:55	12/06/2019 14:40	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance / calibration
13/06/2019 01:00	14/06/2019 11:05	NO, NO <sub>2</sub> , NO <sub>x</sub>	Invalid data - span drift
19/06/2019 10:05	19/06/2019 11:05	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance / calibration
21/06/2019 10:40	25/06/2019 18:25	NO, NO <sub>2</sub> , NO <sub>x</sub>	Instrument fault
21/06/2019 11:40	21/06/2019 11:45	со	Maintenance / calibration
25/06/2019 10:55	25/06/2019 12:10	со	Maintenance / calibration
26/06/2019 11:50	26/06/2019 13:40	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance / calibration
26/06/2019 11:50	26/06/2019 12:50	со	Maintenance / calibration

**Note**: <sup>1</sup> – In the opinion of the reviewer.

#### 9.0 DISCUSSION

## 9.1 Comparison with Licence Limits

EastLink emissions to air from the road tunnel ventilation stacks DP1 and DP2 are subject to the licence requirements contained in Environment Protection Authority (Victoria) Environmental Licence No. 2043 (The Licence).

The maximum measured 1 hour average mass rate for each parameter is compared with the applicable licence limit in Table 27.

Discharge Point No.	Discharge Description	Compound	Mass Rate (kg/h)	Licence Limit (kg/h)
		PM <sub>2.5</sub>	0.21	2.4
	We do not see that an about	PM <sub>10</sub>	0.51	2.6
1	Western ventilation stack	NO <sub>2</sub>	0.81	3.98
		со	13	112
		PM <sub>2.5</sub>	0.21	2.4
		PM <sub>10</sub>	0.56	2.6
2	Eastern ventilation stack	NO <sub>2</sub>	0.90	3.98
		со	11	112

There were no exceedances of the licence limits for DP1 and DP2 during the reporting period.

The procedure for reporting of particulate matter results from the TEOMs and assessment of licence compliance is outlined in the EastLink Particulate Matter Protocol (PMP) dated 17/6/2013 (Golder Reference 107613157-020-R-Rev0). The PMP requires validated uncorrected TEOM one hour clock average data to be reported and compared to the following TEOM mass rate compliance limits for both DP1 and DP2:

There were no exceedances of the  $PM_{10}$  or  $PM_{2.5}$  TEOM mass rate compliance levels for DP1 during the reporting period.

There were no exceedances of the  $PM_{10}$  or  $PM_{2.5}$  TEOM mass rate compliance levels for DP2 during the reporting period.

## 9.2 Data Capture Year to Date

Data capture statistics for 2019 year to date (01/01/2019 - 30/06/2019) are presented in Table 28.



Table 28: Data Capture Year to Date (%)

Station	NO <sub>2</sub>	со	PM <sub>2.5</sub>	PM <sub>10</sub>	Velocity
Eastern	83.7%	94.8%	98.9%	97.4%	100%
Western	92.6%	97.0%	98.3%	98.7%	100%

#### 1.1 Bubble Licence

The Licence contains a Bubble Limit which specifies the annual discharge limits of each parameter for each ventilation stack. Annual emission rates are calculated from 1<sup>st</sup> July to 30<sup>th</sup> June each year to coincide with the Annual Performance Statement (APS) reporting period. Ventilation stack emission rates year to date (1/07/2018 to 30/06/2019) are shown in Table 29.

Table 29: Ventilation Stack Emissions 1/07/2018 - 30/06/2019 (tonnes/year)

Station	NO <sub>2</sub>	со	PM <sub>2.5</sub>	PM <sub>10</sub>
Eastern	1.0	16	0.27	0.47
Western	1.1	17	0.26	0.47
Total	2.1	33	0.53	0.93
Licence limit	35	980	21	23

Figure 20 presents the ventilation stack emissions of each parameter as a percentage of the Licence limit compared with the percentage of APS reporting period elapsed.




Figure 20: Ventilation Stack Emissions as Percentage of Licence Limit (1/07/2018 - 30/06/2019)

## The corresponding bubble limits for uncorrected $PM_{2.5}\,\text{and}\,\,PM_{10}\,\text{TEOM}$ data are:

■ PM<sub>2.5</sub> (DP1 and DP2): 17.5 tonnes/year

■ PM<sub>10</sub> (DP1 and DP2): 17.5 tonnes/year



# Signature Page

**Golder Associates Pty Ltd** 

Anthony Myszka

Environmental Technician

Mark Tulau

M.D ful.

Senior Air Quality Specialist

AM/MDT/am

Golder and the G logo are trademarks of Golder Associates Corporation

 $j:\env\2009\097613024-east link\ stack\correspondence\correspondence\ out\2019\097613024-070-r-rev0\_2019\_q2.docx$ 

#### **APPENDIX A**

Important Information Relating to this Report





#### IMPORTANT INFORMATION RELATING TO THIS REPORT

The document ("Report") to which this page is attached and which this page forms a part of, has been issued by Golder Associates Pty Ltd ("Golder") subject to the important limitations and other qualifications set out below.

This Report constitutes or is part of services ("Services") provided by Golder to its client ("Client") under and subject to a contract between Golder and its Client ("Contract"). The contents of this page are not intended to and do not alter Golder's obligations (including any limits on those obligations) to its Client under the Contract.

This Report is provided for use solely by Golder's Client and persons acting on the Client's behalf, such as its professional advisers. Golder is responsible only to its Client for this Report. Golder has no responsibility to any other person who relies or makes decisions based upon this Report or who makes any other use of this Report. Golder accepts no responsibility for any loss or damage suffered by any person other than its Client as a result of any reliance upon any part of this Report, decisions made based upon this Report or any other use of it.

This Report has been prepared in the context of the circumstances and purposes referred to in, or derived from, the Contract and Golder accepts no responsibility for use of the Report, in whole or in part, in any other context or circumstance or for any other purpose.

The scope of Golder's Services and the period of time they relate to are determined by the Contract and are subject to restrictions and limitations set out in the Contract. If a service or other work is not expressly referred to in this Report, do not assume that it has been provided or performed. If a matter is not addressed in this Report, do not assume that any determination has been made by Golder in regards to it

At any location relevant to the Services conditions may exist which were not detected by Golder, in particular due to the specific scope of the investigation Golder has been engaged to undertake. Conditions can only be verified at the exact location of any tests undertaken. Variations in conditions may occur between tested locations and there may be conditions which have not been revealed by the investigation and which have not therefore been taken into account in this Report.

Golder accepts no responsibility for and makes no representation as to the accuracy or completeness of the information provided to it by or on behalf of the Client or sourced from any third party. Golder has assumed that such information is correct unless otherwise stated and no responsibility is accepted by Golder for incomplete or inaccurate data supplied by its Client or any other person for whom Golder is not responsible. Golder has not taken account of matters that may have existed when the Report was prepared but which were only later disclosed to Golder.

Having regard to the matters referred to in the previous paragraphs on this page in particular, carrying out the Services has allowed Golder to form no more than an opinion as to the actual conditions at any relevant location. That opinion is necessarily constrained by the extent of the information collected by Golder or otherwise made available to Golder. Further, the passage of time may affect the accuracy, applicability or usefulness of the opinions, assessments or other information in this Report. This Report is based upon the information and other circumstances that existed and were known to Golder when the Services were performed and this Report was prepared. Golder has not considered the effect of any possible future developments including physical changes to any relevant location or changes to any laws or regulations relevant to such location.

Where permitted by the Contract, Golder may have retained subconsultants affiliated with Golder to provide some or all of the Services. However, it is Golder which remains solely responsible for the Services and there is no legal recourse against any of Golder's affiliated companies or the employees, officers or directors of any of them.

By date, or revision, the Report supersedes any prior report or other document issued by Golder dealing with any matter that is addressed in the Report.

Any uncertainty as to the extent to which this Report can be used or relied upon in any respect should be referred to Golder for clarification.



golder.com